

Electrical Coordination Study

Performed for the New Electrical System at

[REDACTED]

Located in [REDACTED]

Prepared for

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

Project: [REDACTED]

Attn: [REDACTED]

Subject: Electrical Coordination Study, [REDACTED]

Project Address: [REDACTED]

The electrical system being installed at the above address is designed to provide power to the site through a new medium-voltage service and switchgear. The system will also interface with a new 39.52 kWstc PV system to be installed on the site. The following report will take into consideration the coordination and safety of all devices in the system, pursuant to the following scope:

1. Arc Flash Hazard Report and labels for all DC and AC equipment in the PV system above 50 volts
2. Coordination Study for PV equipment, any customer equipment that was modified, and coordination between PV system and the existing electrical system

Please reference the attached reports as provided:

Appendix A: DC Incident Energy Study

Appendix B: AC Fault and Incident Energy Study

Appendix C: AC & DC Arc Flash Values and Placards

Appendix D: Coordination Study

Appendix E: Summary

We hope this provides the information you require. If you have any questions regarding the contents of our report, or if we can be of further assistance, please contact us.

Respectfully submitted,



Richard Dobbins, PE

Appendix A: DC Incident Energy Study


The total combined DC energy present at the inverter is found to be 39.52 kW DC. Using this value, we can calculate the maximum incident energy at the inverter using the following equation:

$$Incident\ Energy = P \times \frac{1.25 \times T_{exp} \times 3000}{4\pi \times (D \times 2.54)^2} \times 0.239$$

where P is the kW DC power at the inverter, T_{exp} is the exposure time (in seconds), and D is the working distance (in inches). We have assumed T_{exp} to be 2 seconds (typical for DC systems), and D to be 18 inches. In the case of the above inverter, the Incident Energy in the event of an arc was found to be:

$$Incident\ Energy = 39.52 \times \frac{1.25 \times 2 \times 3000}{4\pi \times (18 \times 2.54)^2} \times 0.239 = 2.697\ cal/cm^2$$

Based on the PPE tables provided in NFPA 70E, the minimum arc flash PPE category required for servicing a live PV inverter on this system is category 1.



The above placard shall be affixed to the PV inverter.

Appendix B: AC Fault and Incident Energy Study

The total available fault current supplied by the utility, combined with the new fault current contribution from the PV system, must not exceed the fault rating of the main service panel. We will determine the available fault current at each piece of equipment using the following equations:

$$\text{Fault Current } (I_{AIC}) = \frac{kVA \times 100000}{V \times \sqrt{3} \times \%Z}$$
$$f = \frac{\sqrt{3} \times L \times I_{AIC}}{N \times C \times V} \qquad I_{AIC'} = I_{AIC} \times \frac{1}{1 + f}$$

Where kVA is the transformer rating (in kVA), V is the service voltage (in volts), %Z is the transformer impedance, and L, N, and C are respectively the length (in feet), parallel number, and C constant of conductors between the equipment we are measuring the fault current at and the equipment the fault current is being sourced from.

The estimated utility fault current (using the infinite bus method) at the main service equipment is 14.728 kAIC. We will use the point-to-point calculation method to determine the available fault current at the other equipment in the system, as shown on the following page:

The available utility fault current at the point of service will drop off from the main switchgear, changing as it passes through the MV transformers that are providing power to the site. The PV inverter will also contribute fault current to the system, albeit at a much lower value than that of the utility. Based on manufacturer specifications, each inverter can contribute a maximum of 150% of its rated maximum operational current. For a 33.3kW inverter, this comes out to approximately 60 AIC. Therefore, the maximum potential fault current contribution from the PV inverter at the panel DPA will be 0.060 kAIC, in addition to that seen by the utility.

Using the calculated values for fault current at each piece of equipment in the system, the incident energy and minimum PPE category can be determined.

Using similar values to the ones used to determine the system's DC incident energy, we will use the following equations to determine the incident energy at a piece of equipment:

$$\begin{aligned} \text{Arcing Fault Current } (\log(I_A)) \\ = K_3 + 0.662\log(I_{BF}) + 0.0966V + 0.000526G + 0.5588V\log(I_{BF}) - 0.00304G\log(I_{BF}) \end{aligned}$$

$$\text{Normalized Incident Energy } (E_{in}) = 10^{(K_1 + K_2 + 1.081 \log(I_A) + 0.0011G)}$$

$$\text{Adjusted Incident Energy } (E_i) = 1.5 \times E_{in} \times \left(\frac{T_{exp}}{0.2}\right) \times \left(\frac{610}{D}\right)^X$$

Where I_{bf} is the available bolted fault current at the equipment, I_A is the available arcing fault current at the equipment, K_1 is the configuration constant (assumed to be -0.555 for enclosures), K_2 is the ground constant (assumed to be -0.113 for grounded systems), K_3 is the arc constant (at -0.097), X is the distance exponent (assumed to be approximately 1.5 for enclosures), G is the conductor gap (as defined by the enclosure type), T_{exp} is the exposure time (in seconds), and D is the working distance (in inches). We assumed the T_{exp} for all inverters to be 0.2 seconds (typical for AC systems), and D to be 18 inches. Where T_{exp} is a value other than 0.2 seconds, it is due to the equipment's OCPD providing a different clearing time according to their coordination settings (reference the values under the Coordination Study section at the end of this report).

The difference in bus bolted fault current and bus arc fault current is that the former is the maximum fault current present on the bus and conductors, while the latter is a percentage of that bolted fault current reduced as a function of the resistance of air through which the current flows in the event of an arc flash.

Appendix C: AC & DC Arc Flash Values and Placards

The following table displays the total bolted and arc fault currents available (as the sum of contributions from the utility and PV inverter) at each piece of equipment in the system, as well as the incident energy and arc flash boundary for each.

| Arc Fault Bus Name | Arc Fault Bus kV | Equip Type | Gnd | Electrode Gap (mm) | Bus Bolted Fault (kA)* | Bus Arc Fault (kA) | Trip Time (sec) | Arc Time (sec) | Est Arc Flash Boundary (inches) | Working Distance (inches) | Incident Energy (cal/cm2)** |
|--------------------|------------------|----------------------|-----|--------------------|------------------------|--------------------|-----------------|----------------|---------------------------------|---------------------------|-----------------------------|
| ACDS-1 | 0.48 | Int Switch | X | 32 | 22.776 | 16.849 | 0.2 | 0.2 | 46.6 | 18 | 5.5 |
| ELEV-1 | 0.48 | Other | X | 32 | 19.968 | 14.893 | 0.01 | 0.01 | 8.8 | 18 | 0.4 |
| ELEV-2 | 0.48 | Other | X | 32 | 19.968 | 14.893 | 0.01 | 0.01 | 8.8 | 18 | 0.4 |
| INV-1 | 0.48 | Other | X | 32 | 17.884 | 13.391 | 0.2 | 0.2 | 53.1 | 18 | 6.8 |
| MS1 | 0.48 | Switchboard | X | 32 | 39.024 | 26.235 | 1.954 | 2 | 353.4 | 18 | 139.8 |
| PANEL DPA | 0.48 | Panelboard | X | 25 | 28.194 | 20.916 | 0.2 | 0.2 | 68.1 | 18 | 10.1 |
| PANEL DPB | 0.208 | Panelboard | X | 25 | 12.051 | 5.565 | 8.096 | 2 | 122.9 | 18 | 25.9 |
| PANEL DPC | 0.208 | Panelboard | X | 25 | 7.253 | 3.229 | 0.027 | 0.027 | 5.7 | 18 | 0.2 |
| SWGR-1 | 12.47 | Switchgear | X | 152 | 14.548 | 13.262 | | 1.47 | 242.8 | 18 | 71.0 |
| TX-1 PRI | 12.47 | Transformer Terminal | X | 152 | 14.504 | 13.222 | 1.447 | 1.531 | 248.7 | 18 | 73.7 |
| TX-1 SEC | 0.48 | Transformer Terminal | X | 32 | 39.394 | 26.407 | 1.948 | 2 | 355 | 18 | 140.8 |
| TX-2 PRI | 0.48 | Transformer Terminal | X | 32 | 26.487 | 19.297 | 0.03 | 0.03 | 20.7 | 18 | 1.5 |
| TX-2 SEC | 0.208 | Transformer Terminal | X | 32 | 12.315 | 5.41 | 8.567 | 2 | 127.1 | 18 | 27.3 |
| TX-3 PRI | 0.48 | Transformer Terminal | X | 32 | 21.736 | 16.134 | 0.018 | 0.018 | 13.1 | 18 | 0.7 |
| TX-3 SEC | 0.208 | Transformer Terminal | X | 32 | 11.885 | 5.212 | 0.018 | 0.018 | 6.4 | 18 | 0.2 |
| PANEL L1 | 0.48 | Panel | X | 25 | 2.805 | 2.015 | 0.03 | 0.03 | 3.4 | 18 | 0.08 |
| PANEL L2 | 0.48 | Panel | X | 25 | 21.798 | 16.621 | 0.01 | 0.01 | 7 | 18 | 0.3 |
| PANEL M2 | 0.48 | Panel | X | 25 | 26.487 | 19.821 | 0.03 | 0.03 | 15.5 | 18 | 0.9 |
| PANEL M2A | 0.208 | Panel | X | 25 | 5.967 | 2.61 | 0.025 | 0.025 | 3.7 | 18 | 0.1 |
| PANEL M2B | 0.208 | Panel | X | 25 | 11.101 | 5.104 | 0.025 | 0.025 | 5.8 | 18 | 0.2 |
| PANEL M3 | 0.48 | Panel | X | 25 | 16.885 | 13.006 | 0.04 | 0.04 | 14 | 18 | 0.8 |
| PANEL P1AX | 0.208 | Panel | X | 25 | 5.930 | 2.593 | 0.025 | 0.025 | 3.7 | 18 | 0.1 |
| PANEL P2 | 0.208 | Panel | X | 25 | 10.929 | 5.021 | 0.025 | 0.025 | 4.6 | 18 | 0.1 |
| PANEL P2A | 0.208 | Panel | X | 25 | 10.929 | 5.021 | 0.025 | 0.025 | 4.6 | 18 | 0.1 |
| PANEL P2AX | 0.208 | Panel | X | 25 | 0.650 | 0.236 | 0.025 | 0.025 | 0.8 | 18 | 0.008 |
| PANEL P2BX | 0.208 | Panel | X | 25 | 4.336 | 1.842 | 0.025 | 0.025 | 3 | 18 | 0.07 |
| PANEL R1A | 0.208 | Panel | X | 25 | 7.008 | 3.111 | 0.025 | 0.025 | 4.2 | 18 | 0.1 |
| PANEL R1B | 0.208 | Panel | X | 25 | 3.872 | 1.627 | 0.025 | 0.025 | 2.7 | 18 | 0.06 |
| PANEL R1C | 0.208 | Panel | X | 25 | 6.903 | 3.06 | 0.025 | 0.025 | 4.1 | 18 | 0.1 |
| PANEL R2A | 0.208 | Panel | X | 25 | 5.967 | 2.61 | 0.025 | 0.025 | 3.7 | 18 | 0.1 |
| PANEL R2C | 0.208 | Panel | X | 25 | 11.442 | 5.27 | 0.025 | 0.025 | 5.9 | 18 | 0.2 |
| PANEL R2D | 0.208 | Panel | X | 25 | 10.542 | 4.832 | 0.025 | 0.025 | 5.6 | 18 | 0.2 |
| PANEL R3A | 0.208 | Panel | X | 25 | 5.706 | 2.486 | 0.025 | 0.025 | 3.6 | 18 | 0.09 |
| PANEL R3B | 0.208 | Panel | X | 25 | 5.422 | 2.351 | 0.025 | 0.025 | 3.5 | 18 | 0.09 |
| PANEL DPD | 0.208 | Panel | X | 25 | 11.511 | 5.303 | 0.018 | 0.018 | 4.8 | 18 | 0.1 |
| PANEL RM 251 | 0.208 | Panel | X | 25 | 1.271 | 0.486 | 0.025 | 0.025 | 1.2 | 18 | 0.02 |
| PANEL RM 112 | 0.208 | Panel | X | 25 | 6.279 | 2.759 | 0.025 | 0.025 | 3.9 | 18 | 0.1 |

*Values are including fault contributions from utility and all generation sources - please reference SLD for breakdown of individual contributions

**Refer to NFPA 70E-2018 Table 130.5(G) for PPE requirements

The following labels shall be affixed to the designated equipment (displaying the incident energy, arc flash boundary, and limited and restricted approach boundaries):

 **WARNING**

**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|----------|---|
| 3' - 11" | Arc Flash Boundary |
| 5.5 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: ACDS-1

 **WARNING**

**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 9" | Arc Flash Boundary |
| 0.4 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: ELEV-1

 **WARNING**

**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 9" | Arc Flash Boundary |
| 0.4 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: ELEV-2

 **WARNING**

**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 4' - 5" | Arc Flash Boundary |
| 6.8 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: INV-1

 **WARNING**

**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 7' - 0" | Arc Flash Boundary |
| 14.0 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: MS1

 **WARNING**

**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 5' - 8" | Arc Flash Boundary |
| 10.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL DPA



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|----------|---|
| 10' - 3" | Arc Flash Boundary |
| 25.9 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL DPB



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 6" | Arc Flash Boundary |
| 0.2 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL DPC



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|----------|--|
| 20' - 3" | Arc Flash Boundary |
| 71.0 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Extreme Danger Do not Work on Energized Equipment! |
| 12.47 | kV Shock Hazard when cover is removed |
| 5' - 0" | Limited Approach |
| 2' - 2" | Restricted Approach - Class 2 Voltage Gloves |

Equipment Name: SWGR-1



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 5' - 8" | Arc Flash Boundary |
| 9.6 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 12.47 | kV Shock Hazard when cover is removed |
| 5' - 0" | Limited Approach |
| 2' - 2" | Restricted Approach - Class 2 Voltage Gloves |

Equipment Name: TX-1 PRI



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 7' - 0" | Arc Flash Boundary |
| 14.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: TX-1 SEC



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 1' - 9" | Arc Flash Boundary |
| 1.5 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: TX-2 PRI



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|----------|--|
| 10' - 7" | Arc Flash Boundary |
| 27.3 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy |
| | Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: TX-2 SEC



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|--|
| 1' - 1" | Arc Flash Boundary |
| 0.7 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy |
| | Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: TX-3 PRI



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|--|
| 0' - 6" | Arc Flash Boundary |
| 0.2 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy |
| | Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: TX-3 SEC



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|--|
| 0' - 5" | Arc Flash Boundary |
| 0.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy |
| | Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL DPD



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|--|
| 0' - 3" | Arc Flash Boundary |
| 0.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy |
| | Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL L1



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|--|
| 0' - 7" | Arc Flash Boundary |
| 0.3 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy |
| | Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL L2



WARNING

Arc Flash and Shock Risk Assessment Appropriate PPE Required

| | |
|---------|---|
| 1' - 4" | Arc Flash Boundary |
| 0.9 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL M2



WARNING

Arc Flash and Shock Risk Assessment Appropriate PPE Required

| | |
|---------|---|
| 0' - 4" | Arc Flash Boundary |
| 0.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL M2A



WARNING

Arc Flash and Shock Risk Assessment Appropriate PPE Required

| | |
|---------|---|
| 0' - 6" | Arc Flash Boundary |
| 0.2 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL M2B



WARNING

Arc Flash and Shock Risk Assessment Appropriate PPE Required

| | |
|---------|---|
| 1' - 2" | Arc Flash Boundary |
| 0.8 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.48 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL M3



WARNING

Arc Flash and Shock Risk Assessment Appropriate PPE Required

| | |
|---------|---|
| 0' - 4" | Arc Flash Boundary |
| 0.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL P1AX



WARNING

Arc Flash and Shock Risk Assessment Appropriate PPE Required

| | |
|---------|---|
| 0' - 5" | Arc Flash Boundary |
| 0.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL P2



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 5" | Arc Flash Boundary cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL P2A



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 1" | Arc Flash Boundary cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL P2AX



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 3" | Arc Flash Boundary cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL P2BX



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 4" | Arc Flash Boundary cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL R1A



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 3" | Arc Flash Boundary cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL R1B



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 4" | Arc Flash Boundary cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL R1C



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 4" | Arc Flash Boundary |
| 0.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL R2A



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 6" | Arc Flash Boundary |
| 0.2 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL R2C



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 6" | Arc Flash Boundary |
| 0.2 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL R2D



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 4" | Arc Flash Boundary |
| 0.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL R3A



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 3" | Arc Flash Boundary |
| 0.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL R3B



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 4" | Arc Flash Boundary |
| 0.1 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL RM 112



**Arc Flash and Shock Risk Assessment
Appropriate PPE Required**

| | |
|---------|---|
| 0' - 1" | Arc Flash Boundary |
| 0.0 | cal/cm2 at 18.0 Inches - Arc Flash Incident Energy Refer to NFPA 70E-2018 Table 130.5(G) |

| | |
|---------|---|
| 0.208 | kV Shock Hazard when cover is removed |
| 3' - 6" | Limited Approach |
| 1' - 0" | Restricted Approach - Class 00 Voltage Gloves |

Equipment Name: PANEL RM 251

Appendix D: Coordination Study

All new overcurrent devices that are being installed as a part of the new system have been coordinated to improve their efficacy and response to a short-circuit in the system.

Based on the coordination graphs below (horizontal axis is fault AIC x 100, and vertical axis is time in seconds), all main breakers feeding each subcombiner panel or load panel are coordinated with the breakers in their respective feeder panels to reduce the amount of fault current seen


Coordination Report - Trip Settings

| Relay | | | | | Tap | | | | | | | | Instantaneous | | | |
|--------|--------------|---------|-----------------|----------|------|-----------|---------|----|-----------|---------------------|----------|---------|---------------|----------|---------|------|
| ID | Manufacturer | Type | Device Function | CT Ratio | Name | Range | Setting | PA | Name | Curve | Range | Setting | Name | Range | Setting | PA |
| R-1 | Schweitzer | SEL-351 | 51/50 | 200/5 | Tap | 0.1 - 3.2 | 1.8 | 72 | Time Dial | U3, US Very Inverse | 0.5 - 15 | 0.5 | Inst | 0.25-100 | 9 | 360 |
| | Schweitzer | SEL-351 | 51G/50G | 200/5 | Tap | 0.1 - 3.2 | 0.5 | 20 | Time Dial | U3, US Very Inverse | 0.5 - 15 | 1 | Inst | 0.25-100 | 6 | 240 |
| R-UTIL | Schweitzer | SEL-551 | 51/50 IEEE | 600/5 | Tap | 0.1 - 3.2 | 0.8 | 96 | Time Dial | U3, US Very Inverse | 0.5 - 15 | 1 | Inst | 0.5-80 | 15 | 1800 |
| | Schweitzer | SEL-551 | 51/50N IEEE | 600/5 | Tap | 0.1 - 3.2 | 0.5 | 60 | Time Dial | U3, US Very Inverse | 0.5 - 15 | 1 | Inst | 0.5-80 | 10 | 1200 |


| Solid State Trip Breaker Specifications | | | | | | LTPU | | LT Delay | | STPU | | | | Instantaneous | | | Ground Trip | | | |
|---|--------------|----------------|-----------------|--------------|----------|-----------|----------|----------|-------|-----------|---------|----------|-------|---------------|---------|----------|-------------|--------|----------|-------|
| ID | Manufacturer | Type | Style | Frame/Sensor | tap/plug | Name | Trip (A) | Name | Band | Name | Setting | Trip (A) | Band | I2t | Setting | Override | Trip (A) | Pickup | Trip (A) | Delay |
| DPA-3 | Siemens | ETU 560 | 3VA 400A-LSIG | 400 | 400 | LT Pickup | 400 | tr | 6.5 | ST Pickup | - | - | - | - | 1827 | Pickup | 1827 | 80 | 80 | 0.05 |
| DPA-4 | Siemens | ETU 560 | 3VA 630A-LSIG | 630 | 630 | LT Pickup | 600 | tr | 4.7 | ST Pickup | - | - | - | - | 1777 | Pickup | 1777 | 126 | 126 | 0.05 |
| DPA-5 | Siemens | ETU 560 | 3VA 400A-LSIG | 400 | 400 | LT Pickup | 400 | tr | 10.5 | ST Pickup | - | - | - | - | 1833 | Pickup | 1833 | 80 | 80 | 0.05 |
| DPA-MAIN | Siemens | Sensitrip III | ND | 1200 | 1200 | LT Pickup | 1200 | LT Delay | 2.2 | ST Pickup | 4 | 4800 | 0.1 | Out | 4 | Pickup | 4800 | 0.4 | 480 | 0.1 |
| DPB-1 | GE | Spectra RMS | MCCB SK | 800 | 700 | LT Pickup | 700 | LT Delay | Fixed | ST Pickup | Min | 1050 | Fixed | In | Min | Pickup | 2128 | - | - | - |
| DPB-2 | GE | Spectra RMS | MCCB SF | 250AF(225) | 225 | LT Pickup | 225 | LT Delay | Fixed | ST Pickup | Min | 337.5 | Fixed | In | Min | Pickup | 665 | - | - | - |
| DPB-3 | GE | Spectra RMS | MCCB SE | 100A (100AT) | 100 | LT Pickup | 100 | LT Delay | Fixed | ST Pickup | Min | 150 | Fixed | In | Min | Pickup | 297 | - | - | - |
| DPB-5 | GE | Spectra RMS | MCCB SE | 60A (50AT) | 50 | LT Pickup | 50 | LT Delay | Fixed | ST Pickup | Min | 75 | Fixed | In | Min | Pickup | 148 | - | - | - |
| DPB-MAIN | GE | Spectra RMS | MCCB SK | 800 | 800 | LT Pickup | 800 | LT Delay | Fixed | ST Pickup | 4 | 2400 | Fixed | In | 4 | Pickup | 4912 | - | - | - |
| DPC-1 | GE | Spectra RMS | MCCB SF | 250AF(225) | 225 | LT Pickup | 225 | LT Delay | Fixed | ST Pickup | Min | 337.5 | Fixed | In | Min | Pickup | 665 | - | - | - |
| DPC-2 | GE | Spectra RMS | MCCB SE | 150A (150AT) | 150 | LT Pickup | 150 | LT Delay | Fixed | ST Pickup | Min | 225 | Fixed | In | Min | Pickup | 450 | - | - | - |
| DPC-3 | GE | Spectra RMS | MCCB SE | 100A (70AT) | 70 | LT Pickup | 70 | LT Delay | Fixed | ST Pickup | Min | 105 | Fixed | In | Min | Pickup | 206 | - | - | - |
| DPC-4 | GE | Spectra RMS | MCCB SF | 250AF(225) | 225 | LT Pickup | 225 | LT Delay | Fixed | ST Pickup | Min | 337.5 | Fixed | In | Min | Pickup | 665 | - | - | - |
| DPC-5 | GE | Spectra RMS | MCCB SF | 250AF(225) | 225 | LT Pickup | 225 | LT Delay | Fixed | ST Pickup | Min | 337.5 | Fixed | In | Min | Pickup | 665 | - | - | - |
| DPC-6 | GE | Spectra RMS | MCCB SF | 250AF(225) | 225 | LT Pickup | 225 | LT Delay | Fixed | ST Pickup | Min | 337.5 | Fixed | In | Min | Pickup | 665 | - | - | - |
| DPC-MAIN | GE | Spectra RMS | MCCB SK | 800 | 700 | LT Pickup | 700 | LT Delay | Fixed | ST Pickup | Min | 1050 | Fixed | In | Min | Pickup | 2128 | - | - | - |
| MS1-1200A | Siemens | Sensitrip III | ND | 1200 | 1200 | LT Pickup | 1200 | LT Delay | 2.2 | ST Pickup | 6 | 7200 | 0.05 | Out | 2 | Pickup | 2400 | 0.7 | 840 | 0.2 |
| MS1-450A | Siemens | Sensitrip III | LD | 500 | 500 | LT Pickup | 450 | LT Delay | 3 | ST Pickup | 4 | 1800 | 0.05 | Out | 10 | Pickup | 4500 | 0.55 | 275 | 0.1 |
| MS1-MAIN | Siemens | ETU 745 L(SIG) | ICCB WL FS II-L | 2500(*2T) | 2500 | LT Pickup | 2500 | LT Delay | 2 | ST Pickup | 4 | 10000 | 0.1 | Out | 1.5 | Pickup | 3750 | 1200 | 1200 | 0.2 |

| Thermal Magnetic Breaker Specifications | | | | | Instantaneous | | |
|---|--------------|------|-----------------|------------|---------------|---------|----------|
| ID | Manufacturer | Type | Style | Frame | Trip | Setting | Trip (A) |
| DPA-1 | Siemens | 3VA | 3VA51 H 3P FTAM | 125(40AT) | 40 | 5 | 200 |
| DPA-2 | Siemens | 3VA | 3VA51 H 3P FTAM | 125(40AT) | 40 | 5 | 200 |
| DPA-6 | Siemens | 3VA | 3VA51 H 3P FTAM | 125(100AT) | 100 | 5 | 500 |
| DPA-PV | Siemens | 3VA | 3VA51 H 3P FTAM | 125(50AT) | 50 | 5 | 250 |


CURRENT IN AMPERES X 1000 AT 480 VOLTS




CURRENT IN AMPERES X 10 AT 480 VOLTS




CURRENT IN AMPERES X 100 AT 208 VOLTS




CURRENT IN AMPERES X 100 AT 480 VOLTS




CURRENT IN AMPERES X 10 AT 208 VOLTS




CURRENT IN AMPERES X 10 AT 208 VOLTS




CURRENT IN AMPERES X 100 AT 480 VOLTS




CURRENT IN AMPERES X 10 AT 480 VOLTS




CURRENT IN AMPERES X 10 AT 480 VOLTS



CURRENT IN AMPERES X 100 AT 480 VOLTS




CURRENT IN AMPERES X 10 AT 12470 VOLTS



Utility and Customer Relays - Phase

CURRENT IN AMPERES X 10 AT 12470 VOLTS



Utility and Customer Relays - Ground

Note: SEL-351 shall be programmed using 50G residual-ground overcurrent device function, $I_G = 3I_0 = I_A + I_B + I_C$

Appendix E: Summary

Based on our review of the system's design documents, the provided analysis of the DC and AC arc flash, and the coordination study and accompanying values and settings for all trip devices, the system shall operate as intended and within safety parameters defined by NFPA 70E and the National Electrical Code. It is the responsibility of the electrical contractor to properly install all trip devices, ensure they are programmed according to this report, and that all appropriate labels (or their equivalents) are affixed to all applicable equipment, in accordance with local jurisdictional requirements.

No element of PV system output performance and efficiency was taken into consideration in this report.